



Certificate of Analysis

Page 1 of 1

Client:	Fit & Abel NZ Limited	Lab No:	3162461	SPV1
Contact:	Fit & Abel NZ Limited 553 Williams Street Kaiapoi 7691	Date Received:	30-Jan-2023	
		Date Reported:	31-Jan-2023	
		Quote No:	121767	
		Order No:		
		Client Reference:		
		Submitted By:	Fit & Abel NZ Limited	

Sample Type: Saline

Sample Name:	Fit & Abel NZ 30-Jan-2023 11:24 am
Lab Number:	3162461.1
Enterococci	MPN / 100mL
	< 10

Summary of Methods

The following table(s) gives a brief description of the methods used to conduct the analyses for this job. The detection limits given below are those attainable in a relatively simple matrix. Detection limits may be higher for individual samples should insufficient sample be available, or if the matrix requires that dilutions be performed during analysis. A detection limit range indicates the lowest and highest detection limits in the associated suite of analytes. A full listing of compounds and detection limits are available from the laboratory upon request. Unless otherwise indicated, analyses were performed at Hill Laboratories, 28 Duke Street, Frankton, Hamilton 3204.

Sample Type: Saline

Test	Method Description	Default Detection Limit	Sample No
Enterococci	MPN count using Enterolert, Incubated at 41°C for 24 hours. Analysed at Hill Laboratories - Microbiology; 101c Waterloo Road, Hornby, Christchurch. MIMM 12.4, APHA 9230 D 23 rd ed. 2017.	10 MPN / 100mL	1

These samples were collected by yourselves (or your agent) and analysed as received at the laboratory.

Testing was completed on 31-Jan-2023. For completion dates of individual analyses please contact the laboratory.

Samples are held at the laboratory after reporting for a length of time based on the stability of the samples and analytes being tested (considering any preservation used), and the storage space available. Once the storage period is completed, the samples are discarded unless otherwise agreed with the customer. Extended storage times may incur additional charges.

This certificate of analysis must not be reproduced, except in full, without the written consent of the signatory.

Carla Cuba Bejarano GDipAppSc
Laboratory Technician - Microbiology



This Laboratory is accredited by International Accreditation New Zealand (IANZ), which represents New Zealand in the International Laboratory Accreditation Cooperation (ILAC). Through the ILAC Mutual Recognition Arrangement (ILAC-MRA) this accreditation is internationally recognised. The tests reported herein have been performed in accordance with the terms of accreditation, with the exception of tests marked * or any comments and interpretations, which are not accredited.